



# WELCOME

David Sellers; Senior Engineer, Facility Dynamics Engineering

Commissioning Heat Pump Systems: The Already All Electric Building (and a Potpourri of Topics)

May 29, 2024



# Disclaimer

The information in this document is believed to accurately describe the technologies addressed herein and are meant to clarify and illustrate typical situations, which must be appropriately adapted to individual circumstances. These materials were prepared to be used in conjunction with a free educational program and are not intended to provide legal advice or establish legal standards of reasonable behavior.

Neither Pacific Gas & Electric (PG&E) nor any of its employees and agents: (1) makes any written or oral warranty, expressed or implied, including but not limited to the merchantability or fitness for a particular purpose; (2) assumes any legal liability or responsibility for the accuracy or completeness of any information, apparatus, product, process, method, or policy contained herein; or (3) represents that its use would not infringe any privately owned rights, including but not limited to patents, trademarks or copyrights.

Furthermore, the information, statements, representations, graphs and data presented in this report are provided by PG&E as a service to our customers. PG&E does not endorse products or manufacturers. Mention of any particular product or manufacturer in this course material should not be construed as an implied endorsement.



# Recording Authorization and Release

By attending this event you voluntarily and without compensation consent that Pacific Gas and Electric Company (PG&E), shall have the right to use and assign, photographic pictures, videotapes, recorded testimonials and other media materials or sound recordings, any and all of my name or likeness taken and acquired from our Energy Centers to use to promote or publicize PG&E's business.

Acceptable uses of such Information include but are not limited to: (1) advertising through video/audio commercial broadcasts, written advertisements or other promotional materials about PG&E, whether published by PG&E or another enterprise; (2) news stories or press releases supplied by PG&E to news gathering or disseminating organizations, such as wire services, newspapers, or magazines; and (3) publication in internal or external, PG&E publications.

By participating you agree to release and waive all claims against PG&E from any liability arising from using my Information. You also grant PG&E a perpetual, royalty-free, transferrable license to use my Information to promote its business and expressly disclaim all rights to any value and benefit PG&E may resulting from such use.

# Safety



**Earthquake:**  
Drop  
Cover  
Hold



**Evacuation Plan**



**Review Emergency Plan  
& Pack Go-Bag**



**Stretch,  
Get Up & Move**

Visit: [www.pge.com/emergencypreparedness](http://www.pge.com/emergencypreparedness)

# Class Survey coming...

At the end of this class, we'll share a class survey. We'd love to hear your feedback and if the class met your expectations. Your comments will help us improve future classes.




# Class Survey

The survey should only take 2 minutes and your responses can be confidential.

Here's how to participate:

- Click the provided link:  
<https://www.surveymonkey.com/r/EWB20240529CHP>
- Scan the QR code with your phone's camera



# Using GoTo Webinar

- On the right-hand side of the GoTo panel you will find:

The screenshot shows the GoTo Webinar Control Panel interface. On the left, three callout boxes point to specific sections: an orange arrow labeled 'Handouts Tab' points to the 'Handouts' section; a dark blue arrow labeled 'In-Class Resources' points to the PDF files listed under 'Handouts'; and a light blue arrow labeled 'Questions Tab' points to the 'Questions' section. On the right, three callout boxes provide instructions: a yellow box says 'Click the links to download today's course materials' pointing to the PDF links; a dark blue box says 'Access links to in-class resources & the class survey in the 'Questions' pane' pointing to the question text box; and a light blue box says 'Let's engage! Type your questions in the text box.' pointing to the question input field.

**Handouts Tab**

**In-Class Resources**

**Questions Tab**

**Click the links to download today's course materials**

**Access links to in-class resources & the class survey in the 'Questions' pane**

**Let's engage! Type your questions in the text box.**

**GoToWebinar Control Panel**

**Audio**

- Computer audio
- Phone call
- No audio

**MUTED**

Built-in Microphone

Built-in Output

**Talking:**

Handouts: 2

- PG&E Upcoming Home...Rebates - March 2021.pdf
- Retrofitting Homes For E...rbonization 03.03.21.pdf

**Questions**

Good morning everyone! My name is Javier Montalbo, the Home Performance class coordinator for the PG&E Energy Center.

Type question here.

Send

**Retrofitting Homes for Electrification and Decarbonization**  
Webinar ID# 478-136-683

**GoToWebinar**

# PG&E TLL

## Free energy measurement tool loans and technical assistance

- Over 5,400 tools in our inventory
- 179,000 tool loans over our 29-year history
- Located in San Ramon &
- Pickup in person or ship to borrower (shipping is at your cost)
- Application notes explaining use of tools
- Equipment tutorials
- Equipment troubleshooting
- Assistance on data downloading and analysis

Create your account here

PG&E Tool Lending Library

Create Account | Log In

Home

Inventory

Search Inventory

### PG&E Energy Centers ENERGY MEASUREMENT TOOL LENDING LIBRARY



3301 Crow Canyon Road - C109  
San Ramon, CA, 94583  
USA  
(925) 866-4343

#### PG&E Energy Centers Tool Lending Library

PG&E's free tool lending program provides a wide selection of energy and building measurement tools to customers and professionals working on energy efficiency, demand reduction, demand response, and electrification projects in California.

#### To get started:

1. Log in to your account or [create an account](#) if you haven't already
2. [Create a project description](#) to let us know about your project.
3. Visit our [tool inventory](#) and start the reservation process by clicking on the blue "Reserve" button

When you submit a reservation, you will get a confirmation email. We'll review your reservation and when we approve it you will get an acknowledgement email. Allow two days from the time of your request until you can pick them up. You can pick up in San Ramon or we can ship at your cost.

#### Create a project description

Tell us about your project. If you don't know what tools you want, just click on the button next to "I need assistance selecting items for my project" in your project description. Our staff will contact you to discuss your tool needs.

[Start Here >](#)

#### Get help with your project

The tool lending team can give you expert guidance on the right measurement tools for your project, step by step instructions for each tool, and assist you with your data analysis.

[Contact Us >](#)

[pectools@pge.com](mailto:pectools@pge.com)

925-866-4343

#### What's new?

[Gaslab Plus Multi-Gas Detector CM-504](#)



Contact us:

[www.pge.com/tools](http://www.pge.com/tools)  
[pectools@pge.com](mailto:pectools@pge.com)  
925-866-4343







# Introduction

# Today's Agenda

1. Introduction
2. Conclusion of EBCx effort on the Palm Springs water source heat pump loop.
3. A common VRF system EBCx issue.
4. Introduce the concept of electrification and the all electric building.
5. A closer look at how buildings use heat in the context of the climate they are in.
6. A closer look at coil performance in the context of using recovered energy.
7. A look at the power of an ongoing commissioning process, a dedication to energy efficiency, and creative thinking.
8. All electric building case studies.

# A Bit About Me

(See Module 1 and the Bio on the PG&E Training Site for Details)

A Senior Engineer for Facility Dynamics Engineering Focusing On:

- EBCx
- NCx Support
- Hands-on Technical Training
- System Analysis
- Control System Design



*I Will Tend to Discuss Things in the RCx/Re-Cx/OCx Context (a.k.a Operating the Building Properly)*

# Resources

(See Module 1 for Details)



© Brother Placid Sellers; Saint Vincent Archabbey, Latrobe, Pennsylvania


What's New?

## Buildings are Talking to Us

*We Just Need to Learn How to Listen*


My Goal

# Previously on *Commissioning Heat Pump Systems*



# Water Cooled Heat Pump Loop

March 27, 6 to 9 pm




— Supply Temperature °F  
— Tower Return Temperature °F

— Tower Supply Temperature °F  
— Tower Fan and Pump Current amps

# Does the Pump Head Seem Reasonable?

## Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182




The information on this pump curve was reproduced from the manufacturer's certified performance curves for the purposes of analysis and illustration. To verify certified performance for this pump, refer to the manufacturer's certified performance curve.





# What You Might Learn From the Pump




## Design Condition

- 11 inch impeller
- Design Flow – 320 gpm
- Design Head – 100 ft.w.c.


# Fredrick/Weinman Engineered Products 2 -1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2 -1/2KH-182




# Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182




# What Did You Learn?

What did the pump test results tell you about the closed loop pump performance relative to the design requirement of 320 gpm?




# Fredrick/Weinman Engineered Products 2-1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2-1/2KH-182




# What Did You Learn?

Given the test data and the design flow requirement, is there a way you can predict the head required to deliver the design flow, and thus, the potential savings?




# Fredrick/Weinman Engineered Products 2 -1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2 -1/2KH-182



# What Did You Learn?


What are the options for optimizing the pump?






# Fredrick/Weinman Engineered Products 2 -1/2 KH, 2-1/2 x 3 x 12

Serial Number 110188-1-96, 1 inch pattern 4586 impeller, 20 hp, 1750 rpm, Curve number 2 -1/2KH-182




# What Did You Learn?


If the pump is moving more flow than the design requirement, are there any potential benefits and if so, what are they?



# A Pump In A Different Loop Also Has Something to Say



# A Pump In A Different Loop Also Has Something to Say




It's saying ...

*Help! Help! I'm oversized!*


... just in a different way

# Considering Heat Pump Interactions


Heat pump performance can be impacted by the flows and temperatures in the system




Heat pump performance at different flow rates,  
85°F entering water temperature



# Heat pump performance at different flow rates, 85°F entering water temperature



# Heat pump performand at different entering water temperatures, 3 gpm flow rate



# Bottom Lines

| <b>Findings Summary Table</b>                  |  |                                   | \$0.10 per kWh  | \$0.78 per therm          |                 |                             |                             |                       |                             |                       |
|--|--|-----------------------------------|-----------------|---------------------------|-----------------|-----------------------------|-----------------------------|-----------------------|-----------------------------|-----------------------|
| <b>Item</b>                                    | <b>Finding</b>   | <b>Annual Electricity Savings</b> |                 | <b>Annual Gas Savings</b> |                 | <b>Total Annual Savings</b> | <b>Implementation Costs</b> | <b>Simple Payback</b> | <b>Recommended (Yes/No)</b> | <b>Note Reference</b> |
|  |  | <b>kWh</b>                        | <b>\$</b>       | <b>Therms</b>             | <b>\$</b>       | <b>\$</b>                   | <b>\$</b>                   | <b>Years</b>          |                             |                       |
| <b>Guest Housing Heat Pump Loops</b>           |  |                                   |                 |                           |                 |                             |                             |                       |                             |                       |
| 1  | GHL4 - Potential to vary loop flow rate  | 41,540                            | \$4,154         | 0                         | \$0             | \$4,154                     | \$22,704                    | 5.5                   | Yes                         | Note 2                |
| 2  | GHL2 - Cycle cooling tower pump as 1st stage   | 0                                 | \$0             | 0                         | \$0             | \$0                         | \$0                         | 0.0                   | N/A                         | Note 1                |
| 3  | GHL8 - Bypassing Flow around Heat Exchang  | 0                                 | \$0             | 0                         | \$0             | \$0                         | \$0                         | 0.0                   | No                          |                       |
| 4  | GHL5 - Trim Cooling Tower Pump   | 40,396                            | \$4,040         | 0                         | \$0             | \$4,040                     | \$9,000                     | 2.2                   | Yes                         |                       |
| 5  | GHL1, GHL3 - Optimize closed loop  | 277,192                           | \$27,719        | 48,094                    | \$37,513        | \$65,232                    | \$140,199                   | 2.1                   | Yes                         |                       |
| <b>Total for Guest Housing Heat Pump Loops</b> |  | <b>359,127</b>                    | <b>\$35,913</b> | <b>48,094</b>             | <b>\$37,513</b> | <b>\$73,426</b>             | <b>\$171,903</b>            | <b>2.3</b>            |                             |                       |
| Notes  | 1. This finding has already been implemented by the operating staff  |                                   |                 |                           |                 |                             |                             |                       |                             |                       |
|  | 2 The simple payback for this finding could be as low as 4 years. The energy savings is a conservative estimate. |                                   |                 |                           |                 |                             |                             |                       |                             |                       |
|  | 3 Further investigation is needed to estimate benefits and cost for this measure.                                |                                   |                 |                           |                 |                             |                             |                       |                             |                       |
|  | 4 Energy savings possible is a conservative estimate. The actual savings could be double from the amount listed  |                                   |                 |                           |                 |                             |                             |                       |                             |                       |



# Bottom Lines

Note that none of the savings opportunities are directly related to the heat pumps!

| <b>Findings Summary Table</b>                  |  | \$0.10 per kWh             |                 | \$0.78 per therm   |               |                      |                      |                |                      |                |
|--|--|----------------------------|-----------------|--------------------|---------------|----------------------|----------------------|----------------|----------------------|----------------|
| Item   | Finding  | Annual Electricity Savings |                 | Annual Gas Savings |               | Total Annual Savings | Implementation Costs | Simple Payback | Recommended (Yes/No) | Note Reference |
|  |  | kWh                        | \$              | Therms             | \$            | \$                   | \$                   | Years          |                      |                |
| <b>Guest Housing Heat Pump Loops</b>           |  |                            |                 |                    |               |                      |                      |                |                      |                |
| 1  | GHL4 - Potential to vary loop flow rate  | 41,540                     | \$4,154         | 0                  | \$0           | \$4,154              | \$22,704             | 5.5            | Yes                  | Note 2         |
| 2  | GHL2 - Cycle cooling tower pump as 1st stage   | 0                          | \$0             | 0                  | \$0           | \$0                  | \$0                  | 0.0            | N/A                  | Note 1         |
| 3  | GHL8 - Bypassing Flow around Heat Exchang  | 0                          | \$0             | 0                  | \$0           | \$0                  | \$0                  | 0.0            | No                   |                |
| 4  | GHL5 - Trim Cooling Tower Pump   | 40,396                     | \$4,040         | 0                  | \$0           | \$4,040              | \$9,000              | 2.2            | Yes                  |                |
| 5  | GHL1, GHL3 - Optimize closed loop  | 277,192                    | \$27,719        | 48,094             | \$37,513      | \$65,232             | \$140,199            | 2.1            | Yes                  |                |
| <b>Total for Guest Housing Heat Pump Loops</b> |  | <b>359,127</b>             | <b>\$35,913</b> | <b>48,094</b>      | <b>37,513</b> | <b>\$73,426</b>      | <b>\$171,903</b>     | <b>2.3</b>     |                      |                |
| Notes  | 1. This finding has already been implemented by the operating staff<br>2. The simple payback for this finding could be as low as 4 years. The energy savings is a conservative estimate.<br>3. Further investigation is needed to estimate benefits and cost for this measure.<br>4. Energy savings possible is a conservative estimate. The actual savings could be double from the amount listed |                            |                 |                    |               |                      |                      |                |                      |                |



# VRF Systems (Again)

# Variable Refrigerant Flow Systems

- Key components
  - Indoor unit
  - Outdoor unit
  - Branch Controller
  - Control System
    - Proprietary
    - Limited BACnet integration options
    - Maintenance tool is highly desirable option



# VRF Systems

Taking a closer look at the details

## Variable Flow Refrigeration (VRF) Systems Sequence of Operation

### Overview

The VRF systems associated with this project operate using a proprietary digital control system that manages the interactions of the indoor units serving the occupied zones with the branch controllers and outdoor units serving the system.

The system is served by:

- Two Outdoor Units (ODU) that can serve as conventional condensers to reject heat to the ambient environment or near-conventional heat pumps to extract heat from the ambient environment, and
- Three Branch Controllers (BC) to manage and direct the flow of refrigerant between
- Twenty-five Indoor Units (IDUs) with contain coils that function as evaporators for a cooling cycle and condensers for a heating cycle.

Note that the ODUs are two different sizes and that each ODU contains two compressors. The ODUs are "twinned" which generally means they are piped in parallel and will operate as a unit with the Mitsubishi controllers using one as the master unit and the other as the slave unit, staging the compressors according to the operating mode and requirements of the system to optimize performance and efficiency.

This system configuration will allow:

1. Refrigerant to be sent to the outdoor units operating as conventional condensing units to reject heat if there is a net cooling requirement on the system, or
2. Refrigerant to be sent to the outdoor units operating as heat pumps to capture heat from the outdoors if there is a net heating requirement on the system, or
3. Refrigerant to be redirected from zone to zone for the purposes of heat recovery.

The system diagrams/operating diagrams used in the following section can be viewed as a narrated animation by downloading the Mitsubishi City Multi Refrigerant Flow Animation Application at [www.mylinkdrive.com](http://www.mylinkdrive.com).

### Full Cooling

This operating mode is virtually identical to a conventional direct expansion/vapor compression refrigeration process and is illustrated in Figure 1.

In this mode, refrigerant is evaporated in the coils in all zones to

cool them. The heat is then rejected in the coils at the ODU which causes the refrigerant to condense.

In this operating mode the air leaving the ODU fan will be warmer than the ambient temperature. This condition is used by the control system as an indication that the ODU is in the cooling mode.

### Full Heating

This operating mode is virtually identical to a conventional direct expansion/vapor compression process applied in a heat pump and is illustrated in Figure 2, although the coils in the condenser can use a liquid vapor mix entering them whereas heat pumps often receive only liquid refrigerant and the outdoor coil.

In this mode, refrigerant is condensed in the coils in all zones to heat them. Then, the refrigerant is evaporated in the coils at the ODU, which causes it to pick up heat from the ambient environment for use in heating the indoor zones.

In this operating mode the air leaving the ODU fan will be cooler than the ambient temperature. This condition is used by the control system as an indication that the ODU is in the heating mode.

### Heat Recovery

There are three general operating states associated with the VRF system performing heat recovery.

### Balanced System

This operating mode is illustrated in Figure 3.

In this operating mode, energy is transferred from the zones that require cooling to the zones that require heating with no heat being rejected or picked up at the coils in the ODU. This is the lowest energy state for the system because no ODU fan operation is required and because the refrigerant moving through the system does double duty by first passing through the coils where cooling is required and picking up energy and then moving to the coils where heating is required and giving that energy back up.

In this operating mode, the compressor operates but the ODU fan does not operate. The control system uses this as an indication that the system is in a balanced state.

### More Zones in Heating than Cooling

This operating mode is illustrated in Figure 4.

This operating mode allows the VRF system to concurrently provide heating and cooling with the energy extracted from the zones needing cooling providing energy to the zones that need heat. But because more heat is required than is being recovered from the

zones with a cooling load, the ODU coils are configured to recover heat from the ambient environment and the ODU operates as a heat pump.

As was the case for the full heating mode, the ODU coil receives a mix of liquid and gaseous refrigerant, and the air leaving the ODU fan is cooler than the ambient air. The control system uses the cooler air leaving the ODU fan in combination with a mixed operating state of the VRF Indoor Unit (IDU) zones (some in heating and some in cooling) as an indication that the system is in this operating state.

### More Zones in Cooling than Heating

This operating mode is illustrated in Figure 5.

This operating mode is similar to the operating mode discussed in the preceding paragraph in that it allows the VRF system to concurrently provide heating and cooling with the energy extracted from the zones needing cooling providing energy to the zones that need heat. But because the heat that needs to be rejected by the zones in cooling exceeds the amount of heat required by the zones in heating, the ODU coils receive hot gas and the ODU fan operates to .

As was the case for the full heating mode, the ODU coil receives a mix of liquid and gaseous refrigerant, and the air leaving the ODU fan is cooler than the ambient air. The control system uses the cooler air leaving the ODU fan in combination with a mixed operating state of the VRF Indoor Unit (IDU) zones (some in heating and some in cooling) as an indication that the system is in this operating state.

### Proprietary Digital Control System

The various elements in the VRF system are managed by a stand-alone proprietary digital control system that is capable of providing all of the functionality necessary to operate the system, perform diagnostics, schedule equipment, and track energy consumption including providing web-based access to these features from a central location. However, since the City of Seattle is a sole source Siemens site, the Mitsubishi control system will be integrated with the Siemens control system using BACnet as well as dedicated physical points that are hardwired into the Siemens control system.

The two primary control elements of the Mitsubishi Control network are the Network Manager and the IDU Remote Controllers.

The Mitsubishi AE-200 controller functions as the network manager for the Mitsubishi control system. It shall be furnished

and programmed by the Mitsubishi installing contractor and will be mounted by the Mechanical Instrumentation contractor in an enclosure furnished by the Mechanical Instrumentation contractor.

The Mechanical Instrumentation contractor shall also furnish and install all wiring, raceways and accessories required for a complete wiring system and shall make final terminations to the Mitsubishi equipment in coordination with the Mitsubishi Installing Contractor.

Commissioning shall be performed in conjunction with the Commissioning Provider, the Mitsubishi installing contractor and the Mechanical Instrumentation contractor with support from the design and construction team as required by the contract documents.

The AE-200 provides the following functions for this project.

- Master control functions for the network
- Operation and monitoring of the VRF equipment in the facility
- BACnet functions as required to integrate with the Siemens system
- Web browser access to allow a user with proper credentials to access the system via a web browser for monitoring, operation, energy management, and maintenance functions.

(Continued on sheet MI.8.03-2)



Figure 1 - A VRF System Operating in the Full Cooling Mode



Figure 2 - A VRF System Operating in Full Heating Mode




Figure 3 - A VRF System Operating in a Balanced State




Figure 4 - A VRF System with a Net Heating Requirement on the System



Figure 5 - A VRF System with a Net Cooling Requirement on the System



6700 Alaskan Way, Suite 200  
Seattle, WA 98108  
Phone: (206) 266-0000



APPROVED BY

David J. Smith, P.E.

David J. Smith, P.E.

APPROVED FOR CONSTRUCTION

David J. Smith, P.E.

David J. Smith, P.E.

PROJECT NO: FAS 2010-004

DATE: 04/10/10

DESIGNED BY: CSM

CHECKED BY: CSM

DATE: 04/10/10

REVISIONS:

| NO. | DATE | DESCRIPTION |
|-----|------|-------------|
| 1   |      |             |
| 2   |      |             |
| 3   |      |             |
| 4   |      |             |
| 5   |      |             |
| 6   |      |             |
| 7   |      |             |
| 8   |      |             |
| 9   |      |             |
| 10  |      |             |

SHEET TITLE

VRF System Sequence of Operation Part 1

SHEET NUMBER

MI.8.03-1

# Turn-Down Limitations

VRF systems are often considered to be capable of infinite turn down


- What we take that to mean (would like it to mean)

*subject to no limitation or external determination*



*www.merriam-webster.com*

- Based on vendor discussions “infinite” means
  - 15-20% of rated capacity for the indoor units
  - 19-25% of rated capacity for the outdoor units



# Turn-Down Limitations



# Turn-Down Limitations




# Turn-Down Limitations







# Turn-Down Limitations



# Turn-Down Limitations



# VRF Systems

## VRF Systems: The Good, The Bad and The Ugly

The Commissioning Perspective

David Sellers, PE, Senior Engineer  
Facility Dynamics Engineering  
NW Satellite Office

[www.FacilityDynamics.com](http://www.FacilityDynamics.com)

<https://tinyurl.com/VRFMemo>





# Electrification and the Already All- Electric Building



# Electrification and the Already All-Electric Building

## 560 Mission Street

- 2002
- 31 Floors
- 665,000 sq.ft.
- LEED Platinum
- All Electric

*in anticipation  
of being net-  
zero and  
carbon free*



# Electrification and the Already All-Electric Building

*I have 300 kW of electric resistance heat, and the energy it uses is a major portion of our utility bills. And yet the building is cold!*

Gary Walters, Chief Engineer



Carbon vs. Time vs. Efficiency

# Carbon vs. Time vs. Efficiency

*We expect our energy mix to be 70% carbon free by 2040 based on current commitments and mandates, and we're working to deliver the right resources and technologies to make that happen*

Energy Strategy; [www.portlandgeneral.com](http://www.portlandgeneral.com)

Integrated Resource Planning

Preparing for Oregon's energy future





# Carbon vs. Time vs. Efficiency

## The Current Carbon Impact of Burning Fuel to Make Heat

### CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     |
|-------------|---|---|-----|-----|-----|-----|-----|-----|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

# Carbon vs. Time vs. Efficiency

## The Goal

### CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0   |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)  
 Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

# Carbon vs. Time vs. Efficiency

## The Current Reality

CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     |   | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|---|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |   |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |   |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0 |   |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |   |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |   |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |   |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)  
 Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

| State | % of Total Electric Power Generation |      |       |                   |                           |         |                          |      |       |            |         | Combustion Process Generated Percent of Total | Non-combustion Process Generated Percent of Total |
|-------|--------------------------------------|------|-------|-------------------|---------------------------|---------|--------------------------|------|-------|------------|---------|---|---|
|       | Non-Renewable                        |      |       |                   |                           |         | Renewable                |      |       |            | Nuclear |   |   |
|       | Combustion Processes                 |      |       |                   |                           |         | Non-Combustion Processes |      |       |            |         |   |   |
|       | Coal                                 | Oil  | Gas   | Other Fossil Fuel | Purchased, Fuel Generated | Biomass | Hydro                    | Wind | Solar | Geothermal |         |   |   |
| US    | 19.3%                                | 0.7% | 40.5% | 0.3%              | 0.1%                      | 1.5%    | 7.0%                     | 8.4% | 2.2%  | 0.4%       | 19.6%   | 62.4%   | 37.6%   |

Source - eGRID 2020, Table 4

# Carbon vs. Time vs. Efficiency

## The Current Reality

### CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0   |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)  
 Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

### Heat Rates for Different Types of Power Plants

| Generating Station Type          | Typical Heat Rate |            |         |            |
|----------------------------------|-------------------|------------|---------|------------|
|                                  | Minimum           |            | Maximum |            |
|                                  | Btu/kWh           | Efficiency | Btu/kWh | Efficiency |
| Natural Gas with Cogeneration    | 5,000             | 68%        | 6,500   | 53%        |
| Natural Gas Combined Cycle       | 6,200             | 55%        | 8,000   | 43%        |
| Natural Gas Reciprocating Engine | 7,500             | 46%        | 8,500   | 40%        |
| Natural Gas Combustion Turbine   | 8,000             | 43%        | 10,000  | 34%        |
| Coal Steam Turbine               | 9,000             | 38%        | 11,000  | 31%        |
| Natural Gas Steam Turbine        | 10,000            | 34%        | 12,000  | 28%        |
| Nuclear Power Plant              | 10,446            | 33%        | 10,459  | 33%        |

Heat Rate Source - <https://energyknowledgebase.com/topics/heat-rate.asp>  
 Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

# Carbon vs. Time vs. Efficiency

## The Current Reality

### CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power | lb CO <sub>2</sub> per Million Btu Delivered as Electric Resistance Heat * |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|--|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |  |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |  |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0   | 214  |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |  |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |  |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |  |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)  
 Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

### Heat Rates for Different Types of Power Plants

| Generating Station Type          | Typical Heat Rate |            |         |            |
|----------------------------------|-------------------|------------|---------|------------|
|                                  | Minimum           |            | Maximum |            |
|                                  | Btu/kWh           | Efficiency | Btu/kWh | Efficiency |
| Natural Gas with Cogeneration    | 5,000             | 68%        | 6,500   | 53%        |
| Natural Gas Combined Cycle       | 6,200             | 55%        | 8,000   | 43%        |
| Natural Gas Reciprocating Engine | 7,500             | 46%        | 8,500   | 40%        |
| Natural Gas Combustion Turbine   | 8,000             | 43%        | 10,000  | 34%        |
| Coal Steam Turbine               | 9,000             | 38%        | 11,000  | 31%        |
| Natural Gas Steam Turbine        | 10,000            | 34%        | 12,000  | 28%        |
| Nuclear Power Plant              | 10,446            | 33%        | 10,459  | 33%        |

Heat Rate Source - <https://energyknowledgebase.com/topics/heat-rate.asp>  
 Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

# Carbon vs. Time vs. Efficiency

## The Current Reality

### CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power | lb CO <sub>2</sub> per Million Btu Delivered as Electric Resistance Heat * | lb CO <sub>2</sub> per Million Btu Delivered by a Heat Pump with a COP of 3.7* |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|--|--|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |  |  |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |  |  |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0   | 214  | 91   |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |  |  |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |  |  |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |  |  |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

### Heat Rates for Different Types of Power Plants

| Generating Station Type          | Typical Heat Rate |            |         |            |
|----------------------------------|-------------------|------------|---------|------------|
|                                  | Minimum           |            | Maximum |            |
|                                  | Btu/kWh           | Efficiency | Btu/kWh | Efficiency |
| Natural Gas with Cogeneration    | 5,000             | 68%        | 6,500   | 53%        |
| Natural Gas Combined Cycle       | 6,200             | 55%        | 8,000   | 43%        |
| Natural Gas Reciprocating Engine | 7,500             | 46%        | 8,500   | 40%        |
| Natural Gas Combustion Turbine   | 8,000             | 43%        | 10,000  | 34%        |
| Coal Steam Turbine               | 9,000             | 38%        | 11,000  | 31%        |
| Natural Gas Steam Turbine        | 10,000            | 34%        | 12,000  | 28%        |
| Nuclear Power Plant              | 10,446            | 33%        | 10,459  | 33%        |

Heat Rate Source - <https://energyknowledgebase.com/topics/heat-rate.asp>

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

# Carbon vs. Time vs. Efficiency

## The Current Reality

CO<sub>2</sub> Emissions for Different Fuels

| Fuel        | lb CO <sub>2</sub> per million Btu Burned | lb CO <sub>2</sub> per million Btu Delivered by Boilers |     |     |     |     |     |     | lb CO <sub>2</sub> per Million Btu Delivered Renewable Resources or Nuclear Power | lb CO <sub>2</sub> per Million Btu Delivered as Electric Resistance Heat * | lb CO <sub>2</sub> per Million Btu Delivered by a Heat Pump with a COP of 3.7* |
|-------------|---|---|-----|-----|-----|-----|-----|-----|---|--|--|
|             |   | Boiler Efficiency                                       |     |     |     |     |     |     |   |  |  |
|             |   | 95%   | 90% | 85% | 80% | 75% | 70% | 65% |   |  |  |
| Natural Gas | 117                                       | 123   | 130 | 137 | 146 | 156 | 167 | 179 | 0   | 214  | 91   |
| Propane     | 139                                       | 146   | 154 | 163 | 173 | 185 | 198 | 213 |   |  |  |
| Oil         | 163                                       | 172   | 182 | 192 | 204 | 218 | 234 | 251 |   |  |  |
| Coal        | 212                                       | 223   | 235 | 249 | 265 | 282 | 303 | 326 |   |  |  |

Emissions Factor Source - [https://www.eia.gov/environment/emissions/co2\\_vol\\_mass.php](https://www.eia.gov/environment/emissions/co2_vol_mass.php)

Heat Rate Source - ["Heat Rates" tab of this spreadsheet](#)

\* This is the average value for the various fossil fuel power plants listed in the "Heat Rates" tab

In the transition, burning fossil fuel efficiently to make heat may be better than burning it to make power to make heat

Don't lose sight of energy efficiency

- Just because it's free doesn't mean we can be careless with it
- Don't lose sight of the power of commissioning
- Deliver better new buildings and improve existing buildings

Encourage creative thinking



# Revisiting How Buildings Use Heat



# How Buildings Use Heat

# How Buildings Use Heat



# How Buildings Use Heat

- Preheat Ventilation Air
- Reheat
- Space Heat
  - Radiant slabs
  - Air
  - Finned tube radiation
- Drive Processes
  - Humidification
  - Cooling
  - Sterilization
- Power Generation



# How Buildings Use Heat

- Preheat Ventilation Air
- Reheat
- Space Heat
  - Radiant slabs
  - Air
  - Finned tube radiation
- Drive Processes
  - Humidification
  - Cooling
  - Sterilization



# How Buildings Use Heat

- Preheat Ventilation Air                      50°F - 75°F
- Reheat
- Space Heat
  - Radiant slabs
  - Air
  - Finned tube radiation
- Drive Processes
  - Humidification
  - Cooling
  - Sterilization

# How Buildings Use Heat

- Preheat Ventilation Air                      50°F - 75°F
- Reheat    50°F - 75°F
- Space Heat
  - Radiant slabs
  - Air
  - Finned tube radiation
- Drive Processes
  - Humidification
  - Cooling
  - Sterilization

# How Buildings Use Heat

- Preheat Ventilation Air 50°F - 75°F
- Reheat 50°F - 75°F
- Space Heat
  - Radiant slabs 80°F - 85°F
  - Air 95°F - 110°F
  - Finned tube radiation 120°F – 220°F
- Drive Processes
  - Humidification
  - Cooling
  - Sterilization

# How Buildings Use Heat


- Preheat Ventilation Air 50°F - 75°F
- Reheat 50°F - 75°F
- Space Heat
  - Radiant slabs 80°F - 85°F
  - Air 95°F - 110°F
  - Finned tube radiation 120°F – 220°F
- Drive Processes
  - Humidification 212°F or higher
  - Cooling 212°F or higher; hotter is better
  - Sterilization 300°F or higher



# How Buildings Use Heat

- Preheat Ventilation Air 50°F - 75°F
- Reheat 50°F - 75°F
- Space Heat
  - Radiant slabs 80°F - 85°F
  - Air 95°F - 110°F
  - Finned tube radiation 120°F – 220°F
- Drive Processes
  - Humidification 212°F or higher
  - Cooling 212°F or higher; hotter is better
  - Sterilization 300°F or higher

Low Grade




High Grade


# How Buildings Use Heat in the Context of Climate

A Free Electronic Psych Chart


<https://tinyurl.com/FreePsychChart>



# How Buildings Use Heat in the Context of Climate




# How Buildings Use Heat in the Context of Climate





# How Buildings Use Heat in the Context of Climate




**PSYCHROMETRIC CHART**  
NORMAL TEMPERATURE  
I-P Units  
7 FEET  
BAROMETRIC PRESSURE : 29.915 INCHES OF MERCURY





Weather Data Location:  
SAN FRANCISCO, INTL. AP, ENTHALPY, USA, h  
HUMIDITY RATIO, W, Δv







Weather Data Location:  
 SAN FRANCISCO\_INTL\_AP, CALIFORNIA, USA



# How Buildings Use Heat in the Context of Climate




# How Buildings Use Heat in the Context of Climate






# How Buildings Use Heat in the Context of Climate



# How Buildings Use Heat in the Context of Climate






# Quantifying the Hours with Different Requirements

# Quantifying the Hours with Different Requirements



**PSYCHROMETRIC CHART**  
**NORMAL TEMPERATURE**  
I-P Units  
**7 FEET**  
BAROMETRIC PRESSURE : 29.915 INCHES OF MERCURY



Weather Data Location:  
SAN FRANCISCO, INTL. AP, ENTHALPY, USA, h  
HUMIDITY RATIO, Δw





Chart by: HANDS DOWN SOFTWARE, [www.handsdownsoftware.com](http://www.handsdownsoftware.com)



# Exploring Coil Performance

# Recall That a Reheat Coil Selected for Space Heating Can Do Reheat With Much Cooler Water (i.e. Lower Grade Heat)

<https://tinyurl.com/GreenheckCoilSelection>



**Coil Selection - C-3**

### Review Selection

Review the details of this selection. If everything is in order, press "Finish" to complete. Otherwise, press "Back" to revise your selection.

**Performance** | Construction | Notes | Comment | Pricing

|  |                     |  |            |
|--|---------------------|--|------------|
| Application .....                                    | Hot water           | Fluid .....  | 100% Water |
| Model .....  | HW58S01B09-18x38-RH | Entering fluid temp. (*F) .....                        | 180.0      |
| Air flow (SCFM) .....                                | 1185                | Leaving fluid temp. (*F) .....                         | 160.0      |
| Altitude (ft) .....                                  | 0                   | Fluid delta temp. (*F) .....                           | 20.0       |
| Capacity (MBH) .....                                 | 53.4                | Fluid flow rate (GPM) .....                            | 5.5        |
| Entering air temp. (*F) .....                        | 53.0                | Fluid velocity (ft/s) .....                            | 2.98       |
| Leaving air temp. (*F) .....                         | 94.6                | Fluid pressure drop (ft of water) .....                | 3.1        |
| Face velocity (ft/min) .....                         | 249                 | Fluid fouling factor (h-ft <sup>2</sup> -*F/Btu) ..... | 0.00000    |
| Air pressure drop (in of water) .....                | 0.03                | Fluid freezing temp. (*F) .....                        | 32.0       |
| Air fouling factor (h-ft <sup>2</sup> -*F/Btu) ..... | 0.00000             |  |            |

Help    Go to    < Back    Finish    Cancel



# The Power of Ongoing Cx

(With Heat Pumps)


# The Power of Ongoing Cx





# Another Question

In the context of applying a heat pump is there a benefit to a central plant?




# Central Plant Applications


*Opening the door to recovering energy we have been tossing away all of these years*

# Tracing Energy Through a Facility



















**NOTES**

- This valve is controlled to maintain a heating water temperature of 130 degrees F on the return to the boiler. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature.
- This valve is controlled to maintain a heating water temperature of 130 degrees F on the return to the boiler. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature.
- This valve is controlled to maintain a heating water temperature of 130 degrees F on the return to the boiler. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature.
- This valve is controlled to maintain a heating water temperature of 130 degrees F on the return to the boiler. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature. The valve shall be fully open when the boiler is at normal operating temperature. The valve shall be fully closed when the boiler is at normal operating temperature.

Hot water is stored in the High Pressure Hot Water Storage Tank (HWHST) on the 5th floor. The HWHST is controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The HWHST is controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The HWHST is controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The HWHST is controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler.

These heat exchangers are used to pre-heat the hot water before it enters the boiler. The heat exchangers are controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The heat exchangers are controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The heat exchangers are controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler. The heat exchangers are controlled to maintain a hot water temperature of 130 degrees F on the return to the boiler.

Connectors for hot water piping. Piping to be added when the building is connected to the system. (See Section 25.05.00 for details.)

NOTE: This connection is required for 2 fan coil units per floor level on the 5th floor. The fan coil units shall be controlled to maintain a room temperature of 70 degrees F. The fan coil units shall be controlled to maintain a room temperature of 70 degrees F. The fan coil units shall be controlled to maintain a room temperature of 70 degrees F.

NOTE: Balance valve located in the piping when the 4th floor fan coil units are open.


NOTE: Balance valve located in the piping when the 5th floor fan coil units are open.

Hot Water Return (HWR) piping. Piping to be added when the building is connected to the system. (See Section 25.05.00 for details.)

MATCHLINE - For continuation see 100

MATCHLINE - For continuation see 102

05/11/2018




Heat Exchanger (11-PPH) is a parallel flow heat exchanger. It is used to pre-heat the heating hot water before it enters the boiler. The heat exchanger is located in the boiler room. The heat exchanger is a parallel flow heat exchanger. It is used to pre-heat the heating hot water before it enters the boiler. The heat exchanger is located in the boiler room.

3. These heat exchangers can use very large load fluctuations (i.e. they have large heat sink capacity). The load on them will be at a minimum when they are running on the plant heating water temperature from what is required during the heat recovery period to what is required during the control period. The load on them will be at a maximum when the heating water is in operation due to equipment requirements and/or scheduled changes. For that reason, the heat exchangers are equipped with flow control valves and a special control sequence so that they will avoid chugging operation under all load conditions. One valve is sized for 70% of the heat exchanger capacity and the second valve is sized for 30% of the heat exchanger capacity. The control sequence is as follows: (1) The control valve is closed. (2) The control valve is fully open for a given period of time and will not modulate the desired heating water temperature. (3) The control valve modulates to a setpoint temperature. (4) The large valve modulates the desired set point for a given period of time with the valve to the value of 70% of maximum or less, then the large valve closes and the small valve is modulated down or up as required to maintain the desired control point heating water temperature.

4. Close the bypass valve and then crack it open so all boiler equipped with 3 way valves to control flow to two way operation.

5. Heat exchanger (11-PPH) is a parallel flow heat exchanger. It is used to pre-heat the heating hot water before it enters the boiler. The heat exchanger is located in the boiler room. The heat exchanger is a parallel flow heat exchanger. It is used to pre-heat the heating hot water before it enters the boiler. The heat exchanger is located in the boiler room.

Connect existing Heating W/ing relief valve to the new plant piping system.  
Design flow - 17 gpm @ 50 psi with future 5th and 6th floor.  
Discharge flow - 38 gpm @ 50 psi with future 5th and 6th floor.  
This is the rear of the North end of Heating W/ing pipe through mechanical rooms #4 and #5.




Heating W/ing for call units and outdoor unit heaters (October 5th & 6th Floor provisions)  
Design flow - 150 gpm @ 50 psi with future 5th and 6th floor.  
Discharge flow - 150 gpm @ 50 psi with future 5th and 6th floor.

Opped for future expansion

Repeat valve open as call valve closes.





# A Few Central Plant Bottom Lines

Chilled water is required for surgery when the outdoor temperature reaches 45 - 50°F


- Served by the North Wing Air Cooled Chiller

Chilled water is required by the remainder of the facility when outdoor temperatures exceed 52 – 58°F




- Humidity dependent
- Transition to the Nursing Wing Central Plant

Heat is required year round

- 80 - 90°F works above 65-70°F
- 160 – 180°F required during extreme weather
- 120 – 140°F works during mild weather




# Tracing Energy Through a Facility




# Tracing Energy Through a Facility

## 1. Start with the North Wing AHU Chilled Water Coil



# Tracing Energy Through a Facility


1. Start with the North Wing AHU Chilled Water Coil
2. Pretend you are a Btu that was picked up from the airstream and are now in the chilled water






# Tracing Energy Through a Facility

1. Start with the North Wing AHU Chilled Water Coil
2. Pretend you are a Btu that was picked up from the airstream and are now in the chilled water
3. See if you can get yourself into the heating water system and on your way to a reheat coil



# Another Question

What would you need to do to the North Wing AHU control logic to allow heat to be recovered from it by the central plant during cool weather?






# Getting Back to 560 Mission Street

# Why Is This?

*I have 300 kW of electric resistance heat, and the energy it uses is a major portion of our utility bills. And yet the building is cold!*

Gary Walters, Chief Engineer






# Fan Powered Terminal Units

# Gary's AHU System Diagram


AHU-2-1 / AHU-8-1 through AHU-31-1  
 Motor 20 HP NOM EFF 93 RPM at 60 HZ 1760  
 Fan CFM ~ 18,000  
 Coil Rows 8 GPM 67 MBH SENS. ~ 580

AHU 3-1 through AHU-7-1  
 Motor 25 HP NOM EFF 92.4 RPM at 60 HZ 1760  
 Fan CFM ~ 21,600  
 Coil Rows 8 GPM 84 MBH SENS. ~ 680




|              |      |              |         |
|--------------|------|--------------|---------|
| FPTU Size #1 | ¼ HP | CFM Max 480  | Min 110 |
| FPTU Size #3 | ½ HP | CFM Max 1100 | Min 200 |
| FPTU Size #5 | ¾ HP | CFM Max 1900 | Min 500 |

# Recovering Heat to Reheat Series Fan Powered Box



# Recovering Heat to Reheat Series Fan Powered Box



Fan runs continuously when the zone is occupied


- Tends to be constant volume

Reduction in primary flow (cooling air) is compensated for by increased return flow


- First stage of reheat
- Coil provides second stage



# Recovering Heat to Reheat Series Fan Powered Box



# Recovering Heat to Reheat Parallel Fan Powered Box



Fan runs intermittently when the zone is occupied

- Tends to be constant volume when the fan runs


Zone sees some reduction in flow until the fan starts

- First stage of reheat
- Coil provides second stage



A Typical Fan Powered Box

# The In Series Fan



# The In Series Fan





# Electric Reheat Coils

# Electric Reheat Coils

- Staged control can cause comfort issues
- Silicon Controlled Rectifiers (SCRs) allow modulation



# Electric Reheat Coils

Interaction with other system components needs to be considered

- Fire dampers in line of sight can be a problem
- Temperature sensors in line of sight can be a problem





# Electric Reheat Coils

## Safeties can Cause Issues

- Air flow interlock switch may set the minimum flow rate instead of ventilation requirements



# Electric Reheat Coils

## Safeties can Cause Issues

- Air flow interlock switch may set the minimum flow rate instead of ventilation requirements
- Residual heat can trip high limit safeties after shut down



# Electric Reheat Coils

## Sustainability Implications

- 100% efficient at the coil!
- Run on electricity



# Electric Reheat Coils

## Sustainability Implications

- 100% efficient at the coil!
- Run on electricity
- 30-40% efficient from a source energy standpoint with a fossil fuel fired power plant
- Even with a renewable grid, there will be distribution system losses






# A Paradox


# More Flow $\neq$ More Heating

What happens with this terminal unit control strategy if the minimum flow rate delivers more cooling than the space requires under most of the load conditions it might see?




# More Flow $\neq$ More Heating

| Flow, cfm | Space Temperature, °F | Entering Air, °F | Leaving Air, °F | Capacity, Btu/hr | Simultaneous Heating and Cooling |            | Heat Available to Offset Losses |            |
|-----------|-----------------------|------------------|-----------------|------------------|----------------------------------|------------|---------------------------------|------------|
|           |                       |                  |                 |                  | Btu/hr                           | % of Total | Btu/hr                          | % of Total |
| 650       | 72                    | 52               | 74              | 15,374           | 14,321                           | 93%        | 1,053                           | 7%         |



# More Flow $\neq$ More Heating


| Flow, cfm | Space Temperature, °F | Entering Air, °F | Leaving Air, °F | Capacity, Btu/hr | Simultaneous Heating and Cooling |            | Heat Available to Offset Losses |            |
|-----------|-----------------------|------------------|-----------------|------------------|----------------------------------|------------|---------------------------------|------------|
|           |                       |                  |                 |                  | Btu/hr                           | % of Total | Btu/hr                          | % of Total |
| 650       | 72                    | 52               | 74              | 15,374           | 14,321                           | 93%        | 1,053                           | 7%         |
| 352       | 72                    | 52               | 85              | 12,545           | 7,755                            | 62%        | 4,790                           | 38%        |





# More Flow $\neq$ More Heating

| Flow, cfm | Space Temperature, °F | Entering Air, °F | Leaving Air, °F | Capacity, Btu/hr | Simultaneous Heating and Cooling |            | Heat Available to Offset Losses |            |
|-----------|-----------------------|------------------|-----------------|------------------|----------------------------------|------------|---------------------------------|------------|
|           |                       |                  |                 |                  | Btu/hr                           | % of Total | Btu/hr                          | % of Total |
| 650       | 72                    | 52               | 74              | 15,374           | 14,321                           | 93%        | 1,053                           | 7%         |
| 352       | 72                    | 52               | 85              | 12,545           | 7,755                            | 62%        | 4,790                           | 38%        |
| 151       | 72                    | 52               | 105             | 8,757            | 3,327                            | 38%        | 5,431                           | 62%        |





# Air Distribution Considerations

# Diffusers and Flow Variation

- Need to be designed for the full range of supply flow
- Performance with hot air different from performance with cold air
- Lower average velocity at lower flow rates
  - Less throw
  - Less mixing
  - “Dumping”





What Does All of This Mean?

# What Does All of This Mean?

**All Electric** does not mean **All Done** in terms of opportunities to improve efficiency and performance and reduce atmospheric impact



# What Does All of This Mean?

With a “clean sheet of paper” there may have been some better options


- Electrically fired hot water heat
  - Direct heat recovery from condenser water
  - Heat recovery chillers if higher grade heat is needed
  - Condensing boiler initially for peaking
  - Upgrade to electric boiler in the future



# What Does All of This Mean?

For an existing facility, a commitment to ongoing commissioning along with creative thinking and long-term planning can make a difference


- Electrically fired hot water heat may be an upgrade path in a facility with a long life cycle



# What Does All of This Mean?

For an existing facility, a commitment to ongoing commissioning along with creative thinking and long-term planning can make a difference


- Electrically fired hot water heat may be an upgrade path in a facility with a long life cycle
- Creative thinking can start moving you in the right direction meanwhile







# A Chiller Based Free Cooling Cycle



Condenser

CW Supply and Return

3 Stage Centrifugal Compressor

2 Position Valve (Typical of 2; Open for Free Cooling)


Hot Gas Bypass Valve

Evaporator


Economizer



CHW Supply and Return



Adding "Free Cooling"



"Free Cooling" Operation







# Gary's Chillers can Do This

... and he is using that feature to help solve his heating problem



# The “Trick”

Understanding what “Cooling” and “Heating” Mean in the context of the loads in the facility

## Data Center

“Cooling” means keeping the data center at 80°F

- Can be achieved using 69°F - 72°F “chilled” water
- Resulting return temperatures are in the 74°F – 78°F range


## Office Spaces

“Heating” means warming up spaces that are around 62-65°F

- Can be achieved using 69°F – 72°F “hot water”
- Resulting leaving air temperatures are in the 69°F – 71°F range



# The "Trick"





# Thank You




Together, Building  
a Better California

# Class Survey

The survey should only take 2 minutes and your responses can be confidential.

Here's how to participate:

- Click the provided link:  
<https://www.surveymonkey.com/r/EWB20240529CHP>
- Scan the QR code with your phone's camera





# Break Time

## We will be back at 11:00 am Pacific Time



Together, Building  
a Better California